



FPD-F-1A

**FRESNO FIRE DEPARTMENT  
(NORTH CENTRAL FIRE PROTECTION DISTRICT)  
PRE-INSPECTION CHECKLIST**

(Revised: 07/07/07)

Please inspect your premises for the fire and life-safety items listed below. If item is in compliance with requirements, please place a check on the line. If items are not in compliance, please correct the item(s) as soon as possible. Our goal, as well as yours, is to maintain fire and life-safety and a pleasant environment for you and your patrons. Thank you for your prompt attention to these matters.

**A. EXITS**

Door/Aisle is not obstructed.	Illuminated exit signs maintained in working order.
Proper lock/hardware on exit door.	Clear access around building maintained.
Exit door opens easily.	Evacuation plans known by all employees.
Sign over door "This door to remain unlocked during business hours", if main entrance door is equipped with a double keyed deadbolt.	Doors with panic hardware shall have no other locking devices.

**B. EXTINGUISHER/FIRE PROTECTION EQUIPMENT**

Extinguisher(s) installed as required.	Hood extinguishing system 6-mo. service completed.
Extinguisher has been serviced within the past year and new service tag has been attached.	40B or Class K extinguisher installed for Hood & Duct System.
Extinguisher not obstructed.	Fire alarm system tested at least once a year.
Fire extinguisher top does not exceed 5' from floor as mounted.	18" clearance between storage and sprinkler head.

**C. ELECTRICAL**

No extension cords in use in place of permanent wiring.	Electrical panel is not overloaded/obstructed.
There are no spliced or frayed cords/wires.	No multi-plug adapters in use, other than approved power taps.
Spacer(s) in electrical panel gap(s) provided.	Circuit breakers are labeled.
No broken or faulty switch/outlets.	Electrical cords do not extend through walls, ceilings, floors, under doors, or floor coverings.
No exposed wire not in conduit.	No missing/broken electrical cover plate(s).

**D. APPLIANCE/MECHANICAL DEVICES**

No propane being used in building.	All appliances are properly vented.
------------------------------------	-------------------------------------

**E. STORAGE/COMBUSTIBLE MATERIAL/HOUSEKEEPING**

No combustible material stored near ignition source.	No accumulation of combustible material.
Storage of oily rags in non-combustible container w/lid.	Compressed gas cylinders secured.
Flammable liquid properly stored.	Area around building free of combustible material (weeds, trash, boxes, etc.).
"No Smoking" signs installed as required.	

**F. MISCELLANEOUS**

Street address posted with minimum 3" numbers with contrasting background, visible from street.
---

**NOTE:** This list is a general guideline only for common violations that can be readily determined by the occupant.